



NOTES:

1. THE MINIMUM DIMENSION FROM TOP OF PIPE TO FINISHED GRADE SHALL BE 3.0 FEET.
2. DOUBLE STRAP SADDLE AND WRAP WITH TWO LAYERS OF WIDE PLASTIC OR POLY TAPE WITH STAINLESS STEEL STRAP.
3. PIPE INSTALLATION SHALL BE SUCH THAT THE ARV IS LOCATED AT THE HIGHEST POINT IN THE RESPECTIVE SEGMENT.
4. INTERIOR AND EXTERIOR CONCRETE SURFACES SHALL RECEIVE PROTECTIVE COATING AS SPECIFIED FOR STANDARD MANHOLES.
5. CAST IRON FRAME, COVER AND ACCESS LID SHALL BE INSTALLED FLUSH WITH FINISHED GRADE.
6. COVER SHALL READ "WATER".

## AIR RELEASE VALVE AND VALVE VAULT FOR WATER MAIN

NOT TO SCALE



### City of Leesburg Standard Details



**FARNER  
BARLEY**  
AND ASSOCIATES, INC.

350 North Sholar Avenue • Tavares, Florida 32778 • (352) 343-8481

▲ ENGINEERS  
▲ SURVEYORS  
▲ PLANNERS

April 2004

**Detail W-15**